

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001**

No.F.6/DFS/MS/School/2023/NDZ/ 41

Dated: 20/01/2023

**FIRE SAFETY CERTIFICATE**

Certified that the Universal Public School, located at A Block, Preet Vihar, Delhi 110092, building comprised of Basement + Ground + Three Upper Floors owned / occupied by Universal Public School, was issued Fire Safety Certificate vide letter No. F6/DFS/MS/School/2018/NDZ/2426 Dated 29/10/18. The School building was re-inspected by the officer concerned of this department on 06/01/2023 in presence of Smt. Maya Gupta (Principal) and observed that all the fire prevention and fire safety arrangements provided in the premises found in good working condition. The premises have therefore deemed complied rule 33 of the Delhi Fire Service Rule, 2010 and observed that the building is fit for occupancy class "Educational" (Group-B) with effect from 20/01/2023 for a period of three years in accordance with rule 36 unless renewal under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the DFS rule 2010.

Issued on 20/01/2023 at New Delhi by

  
19/01/23  
(S.K.DUA)

**Dy. CHIEF FIRE OFFICER  
DELHI FIRE SERVICE**

Copy to: -

1. The Principal, Universal Public School, located at A Block, Preet Vihar, Delhi 110092
2. The Director of Education, Govt. of NCT of Delhi, Old Secretariat, Delhi-110054.

**Conditions for the validity of Fire Safety Certificate:**

1. Applicant has given an undertaking dated 03/01/2023 that he will not use newly constructed rooms on 3rd floor and will re-apply before use, failing which NOC / FSC will be treated null and void.
2. All the fire safety arrangement provided there in shall be maintained in good working conditions at all times.
3. Loss of life or property due to non-functional fire safety measure shall be at the responsibility of the Management.
4. The trained fire fighting staff should be available round the clock.
5. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
6. This certificate cannot be treated in any case for regularizations of unauthorized construction.
7. Basement shall be used strictly as per UBBL-2016.
8. "The owner / Occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [subrule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".
9. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in).